

## PUBLIC NOTICE

### IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

#### Sierra Los Pinos HOA Failed to Correct Significant Deficiencies Within Required Time Frame

*Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, o hable con alguien que lo entienda*

Our water system recently violated a drinking water requirement. Although this incident was not an emergency, as our customers, you have a right to know what happened and what we are doing to correct this situation.

A routine sanitary survey conducted on March 3, 2025 by the New Mexico Environment Department-Water Protection Compliance & Enforcement Bureau (NMED WPCEB) found:

**1. 001N- Storage tank - Failure to maintain the storage tank in a manner that is free of leaks, significant structural cracking, corrosion, or advanced concrete spalling.**

As required by Environmental Protection Agency's (EPA's) Ground Water Rule, we were required to correct these deficiencies. However, we failed to take this action by the deadline established by the NMED WPCEB.

#### What should I do?

- There is nothing you need to do. You do not need to boil your water or take other corrective actions. However, if you have specific health concerns, consult your doctor.
- If you have a severely compromised immune system, have an infant, are pregnant, or are elderly, you may be at increased risk and should seek advice from your health care providers about drinking this water. General guidelines on ways to lessen the risk of infection by microbes are available from EPA's Safe Drinking Water Hotline at 1-800-426-4791.

#### What does this mean?

This is not an emergency. If it had been, you would have been notified within 24 hours.

*\*Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.\**

These symptoms, however, are not caused only by organisms in drinking water, but also by other factors. If you experience any of these symptoms and they persist, you may want to seek medical advice.

#### What is being done?

**Corrosion on the System 2 steel tank was noted during a routine inspection in 2023, with a recommendation from the tank service company to recoat or replace in 3-5 years. We are in contact with a tank service about recoating the tank to stop the corrosion, and with the NM Rural Water Association for assistance in identifying appropriate contractors for a replacement or recoating.**

**Although we did not meet our deadline, we are now in consultation with the state to develop a corrective action plan.**

**No leaks have been identified in the tank at this time.**

#### For more information, please contact:

Keith Rigney, [water1@slppoa.org](mailto:water1@slppoa.org)  
Sierra Los Pinos HOA, NM3565423  
950 Forest Road 10  
Jemez Springs, NM 87025

SLPPOA Board, [board1@slppoa.org](mailto:board1@slppoa.org)

*\*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.\**